



Certificate of Compliance

Certificate: 80125191

Date Issued: 2022-04-26

Project: 80125191

Issued to: FreeVolt S.A.
27 Aleja Jana Pawła II
Warszawa, Masovian 00-867
Poland

Attention: Lukasz Nowinski

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



PRODUCTS

CLASS 5311 10 - POWER SUPPLIES - Photovoltaic Modules and Panels

CLASS 5311 90 - POWER SUPPLIES - Photovoltaic Modules and Panels - Certified to U.S. Standards

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M144-BT xxxW (xxx=525-545, in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M120-BT xxxW (xxx=435-455, in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M108-BT xxxW (xxx=385-410, in steps of 5), Fuse rating 30A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M144-HC xxxW (xxx=530-550, in steps of 5), Fuse rating 25A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M120-HC xxxW (xxx=440-460, in steps of 5), Fuse rating 25A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M108-HC xxxW (xxx=390-415, in steps of 5), Fuse rating 25A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M144-HC xxxW Black (xxx=530-550, in steps of 5), Fuse rating 25A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M120-HC xxxW Black (xxx=440-460, in steps of 5), Fuse rating 25A.

Photovoltaic modules with Fire Performance (USA) Type 4, maximum system voltage of 1500 Vdc, model series: ECP-PVGRAF-7M108-HC xxxW Black (xxx=390-415, in steps of 5), Fuse rating 25A.



Certificate: 80125191

Date Issued: 2022-04-26

Project: 80125191

Notes:

1. The electrical characteristics are within + percent of the rated values of I_{sc} , V_{oc} , and P_{max} under standard test conditions (irradiance of 1000 W/m², AM 1.5 spectrum, and a cell temperature of 25°C (77°F)).
2. The operating ambient temperature of these devices may exceed 40 °C at full load for all wire sizes if it is determined suitable in the field use application.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 61730-1:19 Photovoltaic (PV) module safety qualification — Part 1: Requirements for construction, 2019-12.

CSA C22.2 No. 61730-2:19 Photovoltaic (PV) module safety qualification — Part 2: Requirements for testing, 2019-12.

UL 61730-1 1st: Photovoltaic (PV) Module Safety Qualification – Part 1: Requirements for Construction, 2017-12-04, revision date 2020-04-30.

UL 61730-2 1st: Photovoltaic (PV) Module Safety Qualification – Part 2: Requirements for Testing, 2017-12-04, revision date 2020-04-30.

Notes:

Products certified under Class C531110 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca



MARKINGS

Each unit shall bear all the required markings identified in the applicable certification report(s).

FREEVOLT S.A.
Aleja Jana Pawła II 27
00-867 Warszawa
NIP 777 335 73 92, REGON 385291128
KRS 0000821553

**PREZES ZARZADU
FREEVOLT S.A.**

Lukasz Nowiński